future issuances of securities and assumptions of liability, is May 2, 2012.

The Commission encourages electronic submission of protests and interventions in lieu of paper, using the FERC Online links at http://www.ferc.gov. To facilitate electronic service, persons with Internet access who will eFile a document and/or be listed as a contact for an intervenor must create and validate an eRegistration account using the eRegistration link. Select the eFiling link to log on and submit the intervention or protests.

Persons unable to file electronically should submit an original and 14 copies of the intervention or protest to the Federal Energy Regulatory Commission, 888 First Street NE., Washington, DC 20426.

The filings in the above-referenced proceeding are accessible in the Commission's eLibrary system by clicking on the appropriate link in the above list. They are also available for review in the Commission's Public Reference Room in Washington, DC. There is an eSubscription link on the web site that enables subscribers to receive email notification when a document is added to a subscribed docket(s). For assistance with any FERC Online service, please email FERCOnlineSupport@ferc.gov. or call (866) 208–3676 (toll free). For TTY, call $(202)\ 502-8659.$

Dated: April 12, 2012.

Nathaniel J. Davis, Sr.,

Deputy Secretary.

[FR Doc. 2012-9385 Filed 4-18-12; 8:45 am]

BILLING CODE 6717-01-P

DEPARTMENT OF ENERGY

Federal Energy Regulatory Commission

[Project No. 13135-003]

City of Watervliet; Notice of Intent To File License Application, Filing of Pre-Application Document, and Approving Use of the Traditional Licensing Process

- a. *Type of Filing:* Notice of Intent to File License Application and Request to Use the Traditional Licensing Process.
 - b. *Project No.:* 13135–003.
 - c. Date Filed: February 27, 2012.
 - d. Submitted By: City of Watervliet.
- e. *Name of Project:* Delta Hydroelectric Project.
- f. Location: On the Mohawk River, in Oneida County, New York. No federal lands are occupied by the project works or located within the project boundary.

g. *Filed Pursuant to:* 18 CFR 5.3 of the Commission's regulations.

h. *Potential Applicant Contact:* Mr. Mark Gleason, General Manager, City of Watervliet, City Hall, Watervliet, NY 12189 (518) 270–3800 x 122.

i. FERC Contact: Brandi Sangunett at (202) 502–8393; or email at brandi.sangunett@ferc.gov.

j. The City of Watervliet filed its request to use the Traditional Licensing Process on February 27, 2012. The City of Watervliet provided public notice of its request on February 29, 2012. In a letter dated April 12, 2012, the Director of the Division of Hydropower Licensing approved the City of Watervliet's request to use the Traditional Licensing Process.

k. With this notice, we are initiating informal consultation with: (a) The U.S. Fish and Wildlife Service under section 7 of the Endangered Species Act and the joint agency regulations thereunder at 50 CFR, Part 402; (b) NOAA Fisheries under section 305(b) of the Magnuson-Stevens Fishery Conservation and Management Act and implementing regulations at 50 CFR 600.920; and (c) the New York State Historic Preservation Officer, as required by section 106, National Historical Preservation Act, and the implementing regulations of the Advisory Council on Historic Preservation at 36 CFR 800.2.

l. The City of Watervliet filed a Pre-Application Document (PAD; including a proposed process plan and schedule) with the Commission, pursuant to 18 CFR 5.6 of the Commission's regulations.

m. A copy of the PAD is available for review at the Commission in the Public Reference Room or may be viewed on the Commission's Web site (http://www.ferc.gov), using the "eLibrary" link. Enter the docket number, excluding the last three digits in the docket number field to access the document. For assistance, contact FERC Online Support at

FERCONlineSupport@ferc.gov or toll free at 1–866–208–3676, or for TTY, (202) 502–8659. A copy is also available for inspection and reproduction at the address in paragraph h.

n. Register online at http:// www.ferc.gov/docs-filing/ esubscription.asp to be notified via email of new filing and issuances related to this or other pending projects. For assistance, contact FERC Online Support.

Dated: April 12, 2012.

Kimberly D. Bose,

Secretary.

[FR Doc. 2012–9368 Filed 4–18–12; 8:45 am]

BILLING CODE 6717-01-P

DEPARTMENT OF ENERGY

Federal Energy Regulatory Commission

[Project No. 14366-000]

City of New York; Notice of Preliminary Permit Application Accepted for Filing and Soliciting Comments, Motions To Intervene, and Competing Applications

On March 1, 2012, the City of New York filed an application, pursuant to section 4(f) of the Federal Power Act, proposing to study the feasibility of the West of Hudson Hydroelectric Project, which comprises two development sites, Pepacton located on the East Branch of the Delaware River and Neversink located on the Neversink River. The Pepacton Development would be located in Delaware County, New York, and the Neversink Development would be located in Sullivan County, New York.

The proposed West of Hudson Hydroelectric Project would consist of the following developments:

Pepacton Development:

(1) An existing 2,450-foot-long, 204foot-high earthen Downsville Dam; (2) an existing reservoir having a surface area of 5,560 acres and a storage capacity of 441,000 acre-feet and normal water surface elevation of 1,280 feet mean sea level; (3) a proposed powerhouse containing one new generating unit having an installed capacity of 1.7-megawatts; (4) a proposed 80-foot-long, 12.5-kilovolt transmission line; and (5) appurtenant facilities. The proposed Pepacton Development would have an average annual generation of 9.235-gigawatthours.

Neversink Development:

(1) An existing 2,800-foot-long, 195-foot-high earthen Neversink Dam; (2) an existing reservoir having a surface area of 1,478 acres and a storage capacity of 112,000 acre-feet and normal water surface elevation of 1,440 feet mean sea level; (3) a proposed powerhouse containing one new generating unit having an installed capacity of 0.9-megawatt; (4) a proposed 760-foot-long, 12.5-kilovolt transmission line; and (5) appurtenant facilities. The proposed Neversink Development would have an average annual generation of 5.457-gigawatt-hours.

Applicant Contact: Mr. Kevin M. Lang, Esq., Couch White, LLP, 540 Broadway, P. O. Box 22222, Albany, NY 12201–2222, phone (518) 426–4600.

FERC Contact: Timothy Looney; phone: (202) 502–6096.