

from any collateral fire brigade or control room duties they may need to perform as a result of the fire. Operators required to perform the manual actions shall be qualified and continuously available to perform the actions required to achieve and maintain safe shutdown. A training program on the use of operator manual actions and associated procedures during a postulated fire shall demonstrate that operators can successfully achieve these objectives.

4. Communications

To achieve and maintain safe shutdown, adequate communications capability shall be demonstrated for operator manual actions that must be coordinated with other plant operations, with this communications capability continuously available.

5. Special Equipment

Any special equipment required to support operator manual actions, including keys, self-contained breathing apparatus (SCBA), and personnel protective equipment, shall be readily available, easily accessible and demonstrated to be effective.

6. Procedures

Procedural guidance on the use of required operator manual actions shall be readily available, easily accessible and demonstrated to be effective.

7. Local Accessibility

All locations where operator manual actions are performed shall be assessed as accessible without hazards to personnel, with controls needed to assure availability of any special equipment, such as keys or ladders, being demonstrated.

8. Demonstration

The capability to successfully accomplish required operator manual actions within the time allowable using the required procedures and equipment shall be demonstrated using the same personnel/crews who will be required to perform the actions during the fire; documentation of the demonstration shall be provided.

9. Complexity and Number

The degree of complexity and total number of operator manual actions required to effect safe shutdown shall be limited such that their successful accomplishment under realistically severe conditions is assured for a given fire scenario. The need to perform operator manual actions in different locations shall be considered when sequential actions are required. Analyses of the postulated fire time line

shall demonstrate that there is sufficient time to travel to each action location and perform the action required to support the associated shutdown function(s) such that an unrecoverable condition does not occur.

10. Equipment Pre-Conditions

Possible failure modes and damage that may occur to equipment used during a fire shall be considered to the extent that the equipment's subsequent use could be prevented, or at least made difficult. Credit for using equipment whose operability may have been adversely affected by the fire due to smoke, heat, water, combustion products or spurious actuation effects shall account for such possibilities (e.g., over-torquing an MOV due to a spurious signal, as discussed in Information Notice 92-18).

Dated at Rockville, Maryland, this 20th day of November, 2003.

For The Nuclear Regulatory Commission.

Catherine Haney,

Program Director, Policy and Rulemaking Program, Division of Regulatory Improvement Programs, Office of Nuclear Reactor Regulation.

[FR Doc. 03-29560 Filed 11-25-03; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

Regulatory Guide; Issuance, Availability

The Nuclear Regulatory Commission (NRC) has issued a revision of a guide in its Regulatory Guide Series. This series has been developed to describe and make available to the public such information as methods acceptable to the NRC staff for implementing specific parts of the NRC's regulations, techniques used by the staff in its review of applications for permits and licenses, and data needed by the NRC staff in its review of applications for permits and licenses.

Revision 2 of Regulatory Guide 1.53, "Application of the Single-Failure Criterion to Safety Systems," provides guidance on methods acceptable to the NRC staff for satisfying the NRC's regulations with respect to the application of the single-failure criterion to the electrical power, instrumentation, and control portions of nuclear power plant safety systems. This Revision 2 supersedes the recently issued Revision 1, as an incorrect version of the guide was inadvertently issued as Revision 1.

Comments and suggestions in connection with items for inclusion in guides currently being developed or

improvements in all published guides are encouraged at any time. Written comments may be submitted to the Rules and Directives Branch, Division of Administrative Services, Office of Administration, U.S. Nuclear Regulatory Commission, Washington DC 20555. Questions on the content of this guide may be directed to Mr. S.K. Aggarwal, (301) 415-6005; e-mail ska@nrc.gov.

Regulatory guides are available for inspection or downloading at the NRC's Web site at <http://www.nrc.gov> under Regulatory Guides and in NRC's Electronic Reading Room (ADAMS System) at the same site. Single copies of regulatory guides may be obtained free of charge by writing the Reproduction and Distribution Services Section, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, or by fax to (301) 415-2289, or by e-mail to distribution@nrc.gov. Issued guides may also be purchased from the National Technical Information Service (NTIS) on a standing order basis. Details on this service may be obtained by writing NTIS at 5285 Port Royal Road, Springfield, VA 22161; telephone 1-800-553-6847; <http://www.ntis.gov>. Regulatory guides are not copyrighted, and Commission approval is not required to reproduce them. (5 U.S.C. 552(a))

Dated at Rockville, MD, this 17th day of November, 2003.

For The Nuclear Regulatory Commission.

Ashok C. Thadani,

Director, Office of Nuclear Regulatory Research.

[FR Doc. 03-29558 Filed 11-25-03; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

Availability and Solicitation of Public Comments on Interagency Steering Committee on Radiation Standards' Reports on Radioactivity in Sewage Sludge and Ash

AGENCIES: U.S. Nuclear Regulatory Commission and U.S. Environmental Protection Agency.

ACTION: Announce the issuance of three reports concerning radioactivity in sewage sludge and ash, and request public comments.

SUMMARY: This Federal Register notice announces the availability of three reports, prepared by the Sewage Sludge Subcommittee of the Interagency Steering Committee on Radiation Standards (ISCORS), addressing radioactivity in sewage sludge and ash. The first report, "ISCORS Assessment of