

leave to intervene or who has been admitted as a party may amend the petition without requesting leave of the Board up to 15 days prior to the first prehearing conference scheduled in the proceeding, but such an amended petition must satisfy the specificity requirements described above.

Not later than 15 days prior to the first prehearing conference scheduled in the proceeding, a petitioner shall file a supplement to the petition to intervene which must include a list of the contentions which are sought to be litigated in the matter. Each contention must consist of a specific statement of the issue of law or fact to be raised or controverted. In addition, the petitioner shall provide a brief explanation of the bases of the contention and a concise statement of the alleged facts or expert opinion which support the contention and on which the petitioner intends to rely in proving the contention at the hearing. The petitioner must also provide references to those specific sources and documents of which the petitioner is aware and on which the petitioner intends to rely to establish those facts or expert opinion. Petitioner must provide sufficient information to show that a genuine dispute exists with the applicant on a material issue of law or fact. Contentions shall be limited to matters within the scope of the amendment under consideration. The contention must be one which, if proven, would entitle the petitioner to relief. A petitioner who fails to file such a supplement which satisfies these requirements with respect to at least one contention will not be permitted to participate as a party.

Those permitted to intervene become parties to the proceeding, subject to any limitations in the order granting leave to intervene, and have the opportunity to participate fully in the conduct of the hearing, including the opportunity to present evidence and cross-examine witnesses.

If a hearing is requested, the Commission will make a final determination on the issue of no significant hazards consideration. The final determination will serve to decide when the hearing is held.

If the final determination is that the amendment request involves no significant hazards consideration, the Commission may issue the amendment and make it immediately effective, notwithstanding the request for a hearing. Any hearing held would take place after issuance of the amendment.

If the final determination is that the amendment request involves a significant hazards consideration, any

hearing held would take place before the issuance of any amendment.

A request for a hearing or a petition for leave to intervene must be filed with the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, Attention: Rulemakings and Adjudications Staff, or may be delivered to the Commission's Public Document Room (PDR), located at One White Flint North, Public File Area O1F21, 11555 Rockville Pike (first floor), Rockville, Maryland, by the above date. Because of the continuing disruptions in delivery of mail to United States Government offices, it is requested that petitions for leave to intervene and requests for hearing be transmitted to the Secretary of the Commission either by means of facsimile transmission to 301-415-1101 or by e-mail to [hearingdocket@nrc.gov](mailto:hearingdocket@nrc.gov). A copy of the petition for leave to intervene and request for hearing should also be sent to the Office of the General Counsel, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, and because of continuing disruptions in delivery of mail to United States Government offices, it is requested that copies be transmitted either by means of facsimile transmission to 301-415-3725 or by e-mail to [OGCMailCenter@nrc.gov](mailto:OGCMailCenter@nrc.gov). A copy of the request for hearing and petition for leave to intervene should also be sent to [insert attorney name and address], attorney for the licensee.

Nontimely filings of petitions for leave to intervene, amended petitions, supplemental petitions and/or requests for hearing will not be entertained absent a determination by the Commission, the presiding officer or the presiding Atomic Safety and Licensing Board that the petition and/or request should be granted based upon a balancing of the factors specified in 10 CFR 2.714(a)(1)(i)-(v) and 2.714(d).

For further details with respect to this action, see the application for amendment dated May 12, 2003, as supplemented by letter dated December 5, 2003, which is available for public inspection at the Commission's PDR, located at One White Flint North, File Public Area O1F21, 11555 Rockville Pike (first floor), Rockville, Maryland. Publicly available records will be accessible from the Agencywide Documents Access and Management System's (ADAMS) Public Electronic Reading Room on the Internet at the NRC Web site, <http://www.nrc.gov/reading-rm/adams.html>. Persons who do not have access to ADAMS or who encounter problems in accessing the documents located in ADAMS, should contact the NRC PDR Reference staff by

telephone at 1-800-397-4209, 301-415-4737, or by e-mail to [pdr@nrc.gov](mailto:pdr@nrc.gov).

Dated at Rockville, Maryland, this 10th day of December, 2003.

For the Nuclear Regulatory Commission.

**Bhalchandra K. Vaidya,**

*Project Manager, Section 1, Project Directorate IV, Division of Licensing Project Management, Office of Nuclear Reactor Regulation.*

[FR Doc. 03-30961 Filed 12-12-03; 8:45 am]

BILLING CODE 7590-01-P

## NUCLEAR REGULATORY COMMISSION

[Docket No. 50-335]

### Florida Power and Light Company; St. Lucie Plant, Unit No. 1, Environmental Assessment and Finding of No Significant Impact

The U.S. Nuclear Regulatory Commission (NRC) is considering issuance of an exemption from Title 10 of the Code of Federal Regulations (10 CFR) Part 50, Appendix R, Section III.G.2.d for Facility Operating License No. DPR-67, issued to Florida Power and Light Company (the licensee), for operation of the St. Lucie Plant, Unit No. 1, located in St. Lucie County, Florida. Therefore, as required by 10 CFR 51.21, the NRC is issuing this environmental assessment and finding of no significant impact.

#### Environmental Assessment

##### Identification of the Proposed Action

Pursuant to 10 CFR Part 50, Appendix R, Section III.G.2.d, cables and equipment and associated nonsafety circuits of redundant trains located inside noninerted containments are required to be separated by a horizontal distance of more than 20 feet with no intervening combustibles or fire hazards. The proposed action would allow a minimum horizontal separation of 7 feet between redundant cable trays with no intervening combustibles in the containment annular region between column lines 2 and 6.

The proposed action is in accordance with the licensee's application dated October 4, 2000, as supplemented by letters dated June 28, 2001, November 29, 2001, May 15, 2002 and October 22, 2002.

##### The Need for the Proposed Action

On February 21, 1985, the NRC staff approved an exemption from 10 CFR part 50, Appendix R, Section III.G.2.d, to allow cables of redundant trains inside the St. Lucie Unit 1 containment building to be located less than 20 feet

apart horizontally. On March 5, 1987, the NRC staff approved a revision to this exemption to allow minimal intermittent combustibles between the redundant trains. The staff approved the exemptions based, in part, on the redundant trains being separated by more than 7 feet horizontally and 25 feet vertically. The licensee subsequently determined that the assumption of 25 feet vertical separation was incorrect. The proposed action would revise the exemption to eliminate the vertical separation assumption. The licensee provided a fire hazard assessment utilizing a detailed fire model to demonstrate that, with the existing vertical separation and a minimum of 7 feet horizontal separation, a fire in one train will not damage the redundant train. The revised request limits the exemption to the cable trays in the containment annular region between radial column lines 2 and 6 and permits no intervening combustibles.

In summary, the exemption would be revised to allow separation of cables of redundant trains by a horizontal distance of at least 7 feet with no intervening combustibles inside containment in the annular region between radial column lines 2 and 6.

#### *Environmental Impacts of the Proposed Action*

The NRC has completed its evaluation and concludes, as set forth below, that there are no significant environmental impacts associated with the proposed exemption. The details of the staff's safety evaluation will be provided with the exemption when it is issued by the NRC.

The proposed action will not significantly increase the probability or consequences of accidents, there are no significant changes in the types or significant increase in the quantities of effluents that may be released offsite, and there is no significant increase in occupational or public radiation exposure.

With regard to potential nonradiological impacts, the proposed action does not have a potential to affect any historic sites. It does not affect nonradiological plant effluents and has no other environmental impact. Therefore, there are no significant nonradiological environmental impacts associated with the proposed action.

Accordingly, the NRC concludes that there are no significant environmental impacts associated with the proposed action.

#### *Environmental Impacts of the Alternatives to the Proposed Action*

As an alternative to the proposed action, the staff considered denial of the proposed action (*i.e.*, the "no-action" alternative). Denial of the application would result in no change in current environmental impacts. The environmental impacts of the proposed action and the alternative action are similar.

#### *Alternative Use of Resources*

The action does not involve the use of any different resources than those previously considered in the Final Environmental Statement related to the St. Lucie Plant Unit 1, dated June 1973 and Supplement 11 to NUREG-1437, "Generic Environmental Impact Statement for License Renewal of Nuclear Plants Regarding St. Lucie, Units 1 and 2," dated May 2003.

#### *Agencies and Persons Consulted*

On November 3, 2003, the staff consulted with the Florida State official, Mr. William Passeti of the Department of Health, Bureau of Radiation Control, regarding the environmental impact of the proposed action. The State official had no comments.

#### *Finding of No Significant Impact*

On the basis of the environmental assessment, the NRC concludes that the proposed action will not have a significant effect on the quality of the human environment. Accordingly, the NRC has determined not to prepare an environmental impact statement for the proposed action.

For further details with respect to the proposed action, see the licensee's letter dated October 23, 2002, as supplemented on August 28, 2003. Documents may be examined, and/or copied for a fee, at the NRC's Public Document Room (PDR), located at One White Flint North, Public File Area O1F21, 11555 Rockville Pike (first floor), Rockville, Maryland. Publicly available records will be accessible electronically from the Agencywide Documents Access and Management System (ADAMS) Public Electronic Reading Room on the Internet at the NRC Web site, <http://www.nrc.gov/reading-rm/adams.html>. Persons who do not have access to ADAMS or who encounter problems in accessing the documents located in ADAMS should contact the NRC PDR Reference staff at 1-800-397-4209, or 301-415-4737, or by e-mail to [pdr@nrc.gov](mailto:pdr@nrc.gov).

Dated at Rockville, Maryland, this 9th day of December 2003.

For the Nuclear Regulatory Commission.

**Allen G. Howe,**

*Chief, Section 2, Project Directorate II, Division of Licensing Project Management, Office of Nuclear Reactor Regulation.*

[FR Doc. 03-30860 Filed 12-12-03; 8:45 am]

BILLING CODE 7590-01-P

## **NUCLEAR REGULATORY COMMISSION**

[Docket No. 030-00842]

### **Notice of Availability of Environmental Assessment and Finding of No Significant Impact for License Amendment for the University of Minnesota and Release of its Facility in Minneapolis, MN**

**ACTION:** Notice of availability of Environmental Assessment and Finding of No Significant Impact for license amendment.

**FOR FURTHER INFORMATION CONTACT:** Dr. Peter J. Lee, Division of Nuclear Materials Safety, U.S. Nuclear Regulatory Commission, Region III, 801 Warrenville Road, Lisle, Illinois 60532-4351; telephone (630) 829-9870 or by e-mail at [pjl2@nrc.gov](mailto:pjl2@nrc.gov).

#### **SUPPLEMENTARY INFORMATION:**

#### **I. Introduction**

The U.S. Nuclear Regulatory Commission (NRC) is issuing an amendment to University of Minnesota Byproduct Material License No. 22-00187-46, to remove authorization to use radioactive materials from its license for Stone Lab I and II Buildings located at 410 Church Street SE. in Minneapolis, Minnesota, and release the facilities for unrestricted use.

The NRC staff has prepared an Environmental Assessment (EA) in support of this licensing action in accordance with the requirements of 10 CFR Part 51. Based on the EA, the NRC has concluded that a Finding of No Significant Impact (FONSI) is appropriate. The amendment will be issued following publication of this Notice.

#### **II. EA Summary**

The purpose of the proposed action is to allow for the release of the licensee's Stone Lab I and II Buildings located on Minneapolis campus for unrestricted use. The University of Minnesota was authorized by the NRC to use radioactive materials for medical diagnosis, therapy, and research utilizing labeled compounds, such as H-3, C-14, P-32, etc. On September 11, 2003, the University of Minnesota requested that NRC release the facilities