

balancing of the factors specified in 10 CFR 2.714(a)(1)(i)–(v) and 2.714(d).

For further details with respect to this action, see the application for amendment dated March 21, 2000, as supplemented on June 14, 2000, which is available for public inspection at the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, and accessible electronically through the ADAMS Public Electronic Reading Room link at the NRC Web site (<http://www.nrc.gov>).

Dated at Rockville, Maryland, this 18th day of September 2000.

For the Nuclear Regulatory Commission.

**Helen N. Pastis,**

*Senior Project Manager, Section 1, Project Directorate I Division of Licensing Project Management, Office of Nuclear Reactor Regulation.*

[FR Doc. 00–24440 Filed 9–21–00; 8:45 am]

BILLING CODE 7590–01–P

## NUCLEAR REGULATORY COMMISSION

[Docket No. 50–219]

### **AmerGen Energy Company, LLC; Notice of Consideration of Issuance of Amendment to Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity for a Hearing**

The U.S. Nuclear Regulatory Commission (the Commission) is considering issuance of an amendment to Facility Operating License No. DPR–16 issued to AmerGen Energy Company, LLC (the licensee) for operation of the Oyster Creek Nuclear Generating Station located in Ocean County, New Jersey.

The proposed amendment would revise the Technical Specifications (TSs) to establish that the existing Safety Limit Minimum Critical Power Ratio (SLMCPR) contained in TS 2.1.A is applicable for the next operating cycle (Cycle 18).

Before issuance of the proposed license amendment, the Commission will have made findings required by the Atomic Energy Act of 1954, as amended (the Act) and the Commission's regulations.

The Commission has made a proposed determination that the amendment request involves no significant hazards consideration. Under the Commission's regulations in 10 CFR 50.92, this means that operation of the facility in accordance with the proposed amendment would not (1) involve a significant increase in the probability or consequences of an accident previously evaluated; or (2) create the possibility of

a new or different kind of accident from any accident previously evaluated; or (3) involve a significant reduction in a margin of safety. As required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant hazards consideration, which is presented below:

1. *The proposed TS change does not involve a significant increase in the probability or consequences of an accident previously evaluated.*

The derivation of the Cycle 18 SLMCPR for Oyster Creek for incorporation into the TS, and its use to determine cycle-specific thermal limits, has been performed using NRC-approved methods. Additionally, interim implementing procedures, which incorporate cycle-specific parameters, have been used. Based on the use of these calculations, the Cycle 18 SLMCPR of 1.09 will not increase the probability or consequences of an accident.

The basis of the MCPR Safety Limit calculation is to ensure that greater than 99.9% of all fuel rods in the core avoid transition boiling if the limit is not violated. A SLMCPR of 1.09 preserves adequate margin to transition boiling and fuel damage in the event of a postulated accident. The probability of fuel damage is not increased.

Therefore, the proposed TS change does not involve an increase in the probability or consequences of an accident previously evaluated.

2. *The proposed TS change does not create the possibility of a new or different kind of accident from any accident previously evaluated.*

The MCPR Safety Limit is a Technical Specification numerical value designed to ensure that fuel damage from transition boiling does not occur as a result of the limiting postulated accident. The limit cannot create the possibility of any new type of accident. The Cycle 18 SLMCPR has been calculated using NRC-approved methods. Additionally, interim procedures, which incorporate cycle-specific parameters, have been used. Therefore, the proposed TS change does not create the possibility of a new or different kind of accident, from any accident previously evaluated.

3. *The proposed TS change does not involve a significant reduction in a margin of safety.*

The margin of safety as defined in the TS Bases will remain the same. The Cycle 18 SLMCPR is calculated using NRC-approved methods, which are in accordance with the current fuel design and licensing criteria. Additionally, interim implementing procedures, which incorporate cycle-specific parameters, have been used. The MCPR Safety Limit remains high enough to ensure that greater than 99.9% of all fuel rods in the core will avoid transition boiling if the limit is not violated, thereby preserving fuel cladding integrity. Therefore, the proposed TS change does not involve a reduction in a margin of safety.

The NRC staff has reviewed the licensee's analysis and, based on this review, it appears that the three

standards of 10 CFR 50.92(c) are satisfied. Therefore, the NRC staff proposes to determine that the amendment request involves no significant hazards consideration.

The Commission is seeking public comments on this proposed determination. Any comments received within 30 days after the date of publication of this notice will be considered in making any final determination.

Normally, the Commission will not issue the amendment until the expiration of the 30-day notice period. However, should circumstances change during the notice period such that failure to act in a timely way would result, for example, in derating or shutdown of the facility, the Commission may issue the license amendment before the expiration of the 30-day notice period, provided that its final determination is that the amendment involves no significant hazards consideration. The final determination will consider all public and State comments received. Should the Commission take this action, it will publish in the **Federal Register** a notice of issuance and provide for opportunity for a hearing after issuance. The Commission expects that the need to take this action will occur very infrequently.

Written comments may be submitted by mail to the Chief, Rules and Directives Branch, Division of Administrative Services, Office of Administration, U.S. Nuclear Regulatory Commission, Washington, DC 20555–0001, and should cite the publication date and page number of this **Federal Register** notice. Written comments may also be delivered to Room 6D59, Two White Flint North, 11545 Rockville Pike, Rockville, Maryland, from 7:30 a.m. to 4:15 p.m. Federal workdays. Copies of written comments received may be examined at the NRC Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC.

The filing of requests for hearing and petitions for leave to intervene is discussed below.

By October 23, 2000, the licensee may file a request for a hearing with respect to issuance of the amendment to the subject facility operating license and any person whose interest may be affected by this proceeding and who wishes to participate as a party in the proceeding must file a written request for a hearing and a petition for leave to intervene. Requests for a hearing and a petition for leave to intervene shall be filed in accordance with the Commission's "Rules of Practice for Domestic Licensing Proceedings" in 10

CFR Part 2. Interested persons should consult a current copy of 10 CFR 2.714 which is available at the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, and accessible electronically through the ADAMS Public Electronic Reading Room link at the NRC Web site (<http://www.nrc.gov>). If a request for a hearing or petition for leave to intervene is filed by the above date, the Commission or an Atomic Safety and Licensing Board, designated by the Commission or by the Chairman of the Atomic Safety and Licensing Board Panel, will rule on the request and/or petition; and the Secretary or the designated Atomic Safety and Licensing Board will issue a notice of hearing or an appropriate order.

As required by 10 CFR 2.714, a petition for leave to intervene shall set forth with particularity the interest of the petitioner in the proceeding, and how that interest may be affected by the results of the proceeding. The petition should specifically explain the reasons why intervention should be permitted with particular reference to the following factors: (1) The nature of the petitioner's right under the Act to be made party to the proceeding; (2) the nature and extent of the petitioner's property, financial, or other interest in the proceeding; and (3) the possible effect of any order which may be entered in the proceeding on the petitioner's interest. The petition should also identify the specific aspect(s) of the subject matter of the proceeding as to which petitioner wishes to intervene. Any person who has filed a petition for leave to intervene or who has been admitted as a party may amend the petition without requesting leave of the Board up to 15 days prior to the first prehearing conference scheduled in the proceeding, but such an amended petition must satisfy the specificity requirements described above.

Not later than 15 days prior to the first prehearing conference scheduled in the proceeding, a petitioner shall file a supplement to the petition to intervene which must include a list of the contentions which are sought to be litigated in the matter. Each contention must consist of a specific statement of the issue of law or fact to be raised or controverted. In addition, the petitioner shall provide a brief explanation of the bases of the contention and a concise statement of the alleged facts or expert opinion which support the contention and on which the petitioner intends to rely in proving the contention at the hearing. The petitioner must also provide references to those specific sources and documents of which the

petitioner is aware and on which the petitioner intends to rely to establish those facts or expert opinion. Petitioner must provide sufficient information to show that a genuine dispute exists with the applicant on a material issue of law or fact. Contentions shall be limited to matters within the scope of the amendment under consideration. The contention must be one which, if proven, would entitle the petitioner to relief. A petitioner who fails to file such a supplement which satisfies these requirements with respect to at least one contention will not be permitted to participate as a party.

Those permitted to intervene become parties to the proceeding, subject to any limitations in the order granting leave to intervene, and have the opportunity to participate fully in the conduct of the hearing, including the opportunity to present evidence and cross-examine witnesses.

If a hearing is requested, the Commission will make a final determination on the issue of no significant hazards consideration. The final determination will serve to decide when the hearing is held.

If the final determination is that the amendment request involves no significant hazards consideration, the Commission may issue the amendment and make it immediately effective, notwithstanding the request for a hearing. Any hearing held would take place after issuance of the amendment.

If the final determination is that the amendment request involves a significant hazards consideration, any hearing held would take place before the issuance of any amendment.

A request for a hearing or a petition for leave to intervene must be filed with the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, Attention: Rulemakings and Adjudications Staff, or may be delivered to the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, by the above date. A copy of the petition should also be sent to the Office of the General Counsel, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, and to Kevin P. Gallen, Esquire, Morgan, Lewis & Bockius LLP, 1800 M Street, NW., Washington, DC 20036-5869, attorney for the licensee.

Nontimely filings of petitions for leave to intervene, amended petitions, supplemental petitions and/or requests for hearing will not be entertained absent a determination by the Commission, the presiding officer or the presiding Atomic Safety and Licensing Board that the petition and/or request

should be granted based upon a balancing of the factors specified in 10 CFR 2.714(a)(1)(i)-(v) and 2.714(d).

For further details with respect to this action, see the application for amendment dated June 30, 2000, which is available for public inspection at the Commission's Public Document Room, the Gelman Building, 2120 L Street, NW., Washington, DC, and accessible electronically through the ADAMS Public Electronic Reading Room link at the NRC Web site (<http://www.nrc.gov>).

Dated at Rockville, Maryland, this 18th day of September 2000.

For the Nuclear Regulatory Commission.

**Helen N. Pastis,**

*Senior Project Manager, Section 1, Project Directorate 1, Division of Licensing Project Management, Office of Nuclear Reactor Regulation.*

[FR Doc. 00-24441 Filed 9-21-00; 8:45 am]

BILLING CODE 7590-01-P

## NUCLEAR REGULATORY COMMISSION

[Docket No. 72-2]

### Virginia Electric and Power Company Issuance of Environmental Assessment and Finding of No Significant Impact Regarding the Proposed Amendment to Revise Technical Specifications of License No. SNM-2501

The U.S. Nuclear Regulatory Commission (NRC or Commission) is considering issuance of an amendment, pursuant to 10 CFR 72.56, to Special Nuclear Material License No. 2501 (SNM-2501) held by Virginia Electric and Power Company (Virginia Power) for the Surry independent spent fuel storage installation (ISFSI). The requested amendment would revise the Technical Specifications (TS) of SNM-2501 to specifically permit the use of the TN-32 storage cask to store spent fuel with a higher initial enrichment and burnup than currently specified in the TS for the Surry ISFSI.

#### Environmental Assessment (EA)

*Identification of Proposed Action:* By letter dated November 15, 1999, as supplemented, Virginia Power requested an amendment to revise the TS of SNM-2501 for the Surry ISFSI. The changes would specifically permit the use of the TN-32 storage cask to store spent fuel with a higher initial enrichment and burnup than currently specified in the TS. Currently the TS for the Surry ISFSI limit the fuel to be stored in the TN-32 to the following: initial enrichment of  $\leq 3.85$  % (wt U-235), assembly average burnup of  $\leq$